ACKNOWLEDGEMENT AND RECORD OF SPCC INSPECTION AND PLAN REVIEW BULK STORAGE FACILITIES

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY - REGION 6

1445 Ross Avenue, 6 SF-RO, Dallas, Texas 75202-2733

SPCC Case #: FY-INSP- 090 18 7	
SPCC Inspection Date: 8/24/69 Time: 9:00 P.M.	FRP Inspection Date: 2 24 109 Time: 9 00 A N
Name of Facility: Ft, Smith Terminal	
Latitude: N 35° 19' 34'' Longitude: w - 94'	Source: FRP
Facility Address/Location: 8101 12-wg 71 500	w4h
☐ Tribal Land Reservation Name:	
City: _ F b. S m b County/Parish: _ 5	cbast 19m State: 14 12 Zip: 72903
Facility Contact: Douglas Hammer	Title: Supercos ex Openetrony & Mem
Telephone Number: 479 - 64 6 - 1721	Email:
Name of Owner/Operator: Magellan P	Pipeline company, LP
Address: one williams center - P.a.	[19일본] : 1일 : 이 그는 그 사람이 되었다면 하면 그는 그는 그는 그는 그는 것이 없는 것이 없는 것이다.
City: Tulsa	그 집안된하는 그 그 없는데 그 그리는 해서를 하는데 하는데, 얼마를 하는데 그리는 그 없지만 하는데
Contact:	Title:
Telephone Number: 918 - 578 - 7310	Email:
Synopsis of Business: Storage & DTS Inches	
Synopsis of Business: 5 toras - > 0 75 hi hade	ion of refined periodeem products
How many employees work at this facility?	NAICS#:
How many employees work at this facility? If unmanned, how many employees maintain this facilit	ty?
How many employees work at this facility? If unmanned, how many employees maintain this facilit Is the Facility: Unattended Attended Daily (8 hr)	NAICS #: Daily (24 hr) Periodically)
How many employees work at this facility? If unmanned, how many employees maintain this facilit	NAICS #: Daily (24 hr) Periodically)
How many employees work at this facility? If unmanned, how many employees maintain this facilit Is the Facility: Unattended Attended Daily (8 hr) Route of Entry to Waterway:	NAICS #: Daily (24 hr) Periodically)
How many employees work at this facility? If unmanned, how many employees maintain this facilit Is the Facility: Unattended Attended Daily (8 hr) Route of Entry to Waterway: Distance to waterway (in feet):	NAICS #: Daily (24 hr) Periodically)
How many employees work at this facility? If unmanned, how many employees maintain this facilit Is the Facility: Unattended Attended Daily (8 hr) Route of Entry to Waterway: Distance to waterway (in feet): Relative direction to water body:	NAICS #: Daily (24 hr) Periodically) Elevation above water body (ft):
How many employees work at this facility? If unmanned, how many employees maintain this facilit Is the Facility: Unattended Attended Daily (8 hr) Route of Entry to Waterway: Distance to waterway (in feet): Relative direction to water body: SPCC inspector name:	NAICS #: Daily (24 hr) Periodically) Elevation above water body (ft): FRP inspector name:
How many employees work at this facility? If unmanned, how many employees maintain this facilit Is the Facility: Unattended Attended Daily (8 hr) Route of Entry to Waterway: Distance to waterway (in feet): Relative direction to water body:	NAICS #: Daily (24 hr) Periodically) Elevation above water body (ft): FRP inspector name: Team members:
How many employees work at this facility? If unmanned, how many employees maintain this facilit Is the Facility: Unattended Attended Daily (8 hr) Route of Entry to Waterway: Distance to waterway (in feet): Relative direction to water body: SPCC inspector name: Team members:	NAICS #: Daily (24 hr) Periodically) Elevation above water body (ft): FRP inspector name: Team members:
How many employees work at this facility? If unmanned, how many employees maintain this facilit Is the Facility: Unattended Attended Daily (8 hr) Route of Entry to Waterway: Distance to waterway (in feet): Relative direction to water body: SPCC inspector name: Team members:	NAICS #: NAICS #: Daily (24 hr) Periodically) Elevation above water body (ft): FRP inspector name: Dan Smith Team members: Tow meks; mise clan
How many employees work at this facility? If unmanned, how many employees maintain this facilit Is the Facility: Unattended ☐ Attended(☐ Daily (8 hr)) Route of Entry to Waterway: Distance to waterway (in feet): Relative direction to water body: SPCC inspector name: Team members: SPCC Plan review by: Date of review:	NAICS #: NAICS #:
How many employees work at this facility? If unmanned, how many employees maintain this facilit Is the Facility: Unattended Attended Daily (8 hr) Route of Entry to Waterway: Distance to waterway (in feet): Relative direction to water body: SPCC inspector name: Team members: SPCC Plan review by: Date of review:	NAICS #: NAICS #:
How many employees work at this facility? If unmanned, how many employees maintain this facilit Is the Facility: Unattended Attended Daily (8 hr) Route of Entry to Waterway: Distance to waterway (in feet): Relative direction to water body: SPCC inspector name: Team members: SPCC Plan review by: Date of review:	NAICS #: NAICS #:

9490520

Page 1

		Memorandui (check all app			SAC STATE OF			
Non-Tra	nsportation R	Related	13.79	100 100 1200	Tran	sportation Re	lated	
EPA		13	US	SCG		☐ MMS		OPS
		Fa	cility T	ype				
Onshore Oil:				Offshore	Oil:			
☐ Production		Drilling/workover		☐ Drilling	, Produ	ction and Work	over	
Bulk Storage (chec	ck all applicable	descriptions)						
Aviation	☐ Federal	Facility	D P	etroleum Di	stributo		Service S	Station
☐ Animal Fats & Oils	☐ Gatherin	ng Facility	Pe	etroleum Ma	rketing	Terminal	Transpor	rter (Truck/Rail)
☐ Asphalt Paving	☐ Hospita	1	Pi	peline Bulk	Storage		Tribal	
☐ Asphalt Coatings	☐ Manufac	cturing, Lube/Grease	Ra	ailroad			Utilities	
☐ Auto Dealership	☐ Marina		Re	emediation/l	Recyclin	ng 🗆	State	
☐ Bulk Packing	☐ Military		Re	efinery			Local	
☐ Concrete/Cement	☐ Mining		Re	ental Car Co	mpany		Other:	
Crude Petroleum	☐ Natural	Gas Liquids		and & Grav		у		
Farm	Petroch	emical	□ S	chool/Unive	rsity		1 11 21	Mark Comment
Aboveground Stora Mobile/portable sunits			ents [Drums Lagoons nction edescriptions		In-plant piping Equipment	Othe	er containers
Transferring [Distributing	Processing	☐ Ga	athering	□ Co	onsuming/Using		Operations
		Facility S	torage	Capacitie	s			
AST Storage Capacity		UST Storage Ca	apacity (gal):		Total Facility (
Types of Oil Stored: Crude oil Other:	Gasoline	☐ Diesel ☐ F	uel oil	☐ Jet t	fuel	☐ Vegetable	oil/animal	fats, grease
Qualified Facility Three	sholds : 🔲 <5	,000 Gallons				The state of the last	•	YES NO
The aggregate aboves	ground storage	e capacity is 10,000 G	allons or	r less 112.3(g)(1) AN	D		YES NO
The facility has had no discharges exceeding Plan self-certification of than three years. (No included in this qualific	o single discha 42 U.S. gallon date, or since t te: Oil discharg	rge exceeding 1,000 to as within any twelve-more to the decoming subject to the ges that result from na	U. S. gal nonth pe ne rule if	llons, and the riod in the to	ne facilit ree year has bee	y has had no tw rs prior to the SI n in operation for	PCC or less	YES NO
Is the facility considered certified the SPCC Plan,				above, AND	the owr	ner/operator has se	elf	YES NO

GENERAL APPLICABILITY - 40 CFR 112.1	7.00
Does the facility maintain an aggregate aboveground oil storage capacity of over 1,320 gallons, and/or completely buried oil storage capacity of over 42,000 gallons? VES NO and	
Is the facility engaged in drilling, producing, gathering, storing, processing, refining, transferring, distributing, using, or consuming oil and oil products, which due to its location could reasonably be expected to discharge oil into or upon the navigable waters of the United States (as defined in 40 CFR 110.1)? YES NO If YES to both, the facility is regulated under 40 CFR 112.	
Note: The following storage capacity is not considered in determining applicability of SPCC requirements: - Completely buried tanks subject to all the technical requirements of 40 CFR 280 or a state program approved under 40 CFR 281. - Equipment subject to the authority of the U.S. Department of Transportation, U.S. Department of the Interior, or Minerals Management Service, as defined in Memoranda of Understanding dated November 24, 1971, and November 8, 1993. - Any facility or part thereof used exclusively for wastewater treatment and not used to satisfy SPCC requirements. - Containers smaller than 55 gallons. - Permanently closed containers.	

FACILITY RESPONSE PLAN (FRP) APPLICABILITY		
Does the facility transfer oil over water to or from vessels and has a total oil storage capacity greater than or equal to 42,000 gallons?		□ YES □NO
Or, Does the facility have a total oil storage capacity of at least 1 million gallons, And, at least one of the following is true:	· (YES NO
The facility does not have secondary containment sufficiently large enough to largest aboveground tank plus sufficient freeboard for precipitation.	contain the capacity of the	YES NO
The facility is located at a distance such that a discharge could cause injury to sensitive environments.	to fish and wildlife and	YES NO
The facility is located such that a discharge would shut down a public drinkin	g water intake.	YES NO
The facility has had a reportable discharge greater than or equal to 10,000 g	allons in the past 5 years.	YES NO
If YES to any of the above, the facility is a non-transportation related onshore faimplement a FRP as outlined in 40 CFR 112.20.	cility required to prepare and	
Does the facility maintain a FRP? ☐YES ☐ NO ☐ Not Required	FRP Number: FRP-06- P-12-	00053
Does the Plan include a signed copy of the Certification of the Applicability of the per 40 CFR Part 112.20(e)? Attachment C-II	e Substantial Harm Criteria	YES NO
Comment:		
* 10 P. T.		

REQUIREMENTS FOR PREI	PARATION AND IMPLEMENTATION	ON OF A SPCC Plan - 40 CFR 112.3
Facility Startup Date:	Date of initial SPCC Plan preparat	ion: Current Plan version (date/number):
For facilities (excluding farms) in 112.3(a) YES NO NO		s the Plan amended and implemented by July 1, 2009?
For facilities (excluding farms) be implemented by July 1, 2009? 1	eginning operation between August 17, 12.3(a) YES NO NO N/A	2002 and July 1, 2009, is the Plan prepared and fully
For facilities beginning operation YES NO NO NA	after July 1, 2009, was the Plan imple	nented before beginning operations? 112.3(b) & (c)
Is an SPCC Plan prepared?	YES NO NA	
Professional Engineer certification	on must include statements that the PE	attests to. 112.3(d)
He/she is familiar with the requir	ements of the SPCC rule. (i) YES	□ NO □ N/A
He/she or his/her agent has visi	ited and examined the facility. (ii)	YES NO N/A
	accordance with good engineering praenents of the SPCC rule. (iii) YES	tice, including consideration of applicable industry NO N/A
Procedures for required inspecti	ons and testing have been established	iv) ☐ YES ☐ NO ☒ N/A
The Plan is adequate for the fac	ility. (v) 🗌 YES 🗎 NO 🔯 N/A	
Is the SPCC Plan fully PE certifi	ed? 112.3(d) YES NO	Date of Certification: 6/13/2013
Name of Professional Engineer:	Robert D. Shall	
License Number: 698	State:	AR
Is an SPCC Plan available for re	eview? YES NO Is an !	SPCC Plan maintained on site? YES NO
(During normal working hours)	112.3(e)(2) (For a 112.3(e)	t least 4 hours/day, excluding oil production facilities)
AMENDMENT OF SPCC PL	AN BY REGIONAL ADMINISTRA	TOR (RA)—40 CFR 112.4
Have there been reportable spill	ls at this facility of more than 1,000 gall	ons? 112.4(a)
Or, has the facility had two spills	s of more than 42 gallons in the past 12	months? 112.4(a) YES NO N/A
	n submitted to the RA as required in §1	2.4(a)? YES NO N/A
Date of spills:		
If applicable, have changes requ	uired by the RA been implemented in th	e Plan and/or facility? 112.4(d), (e)
Comment:		

Has there been any change of facility design (construction, operation, or maintenator discharge? (112.5a) YES NO N/A	ance) that could affect the	he facility's potential
If YES, was the amendment within 6 months and was a plan change Yes	No or a design char	nge □ Yes □ No
le the SDCC Dies reviewed and avaluated area of 50000 DI NO DI		
Is the SPCC Plan reviewed and evaluated every 5 years? YES NO		50 -
If amended and implemented (if necessary), is it documented in the Plan (sign off Date of latest change: Certification #:	sheet)? 112.5(b) YE	ES NO N/A
Date of latest change Certification #		
Name of PE certifying amendments 112.5(c) (Except for self certified Plans):		
License #: State: Date of Certification:		
Reason for amendment:	P 5 1 2 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7	
Comment:		

	THE RESERVE OF THE PARTY OF THE	12224
GENERAL REQUIREMENTS FOR SPCC PLANS 112.7(a-d)	Plan Review	Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7	Plan Review	Field Verification
Does the SPCC Plan indicate (by signature and date) that management has		Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7		Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7 Mgmt Personnel Name: Doug Hammer.		Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7 Mgmt Personnel Name: Doug Hammer. Mgmt Personnel Title:	YES THO N/A	Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7 Mgmt Personnel Name: Mgmt Personnel Title: Sugardian Grand Name: Does the Plan format follow the sequence in the rule? 112.7 or If no, is a cross-reference provided?	YES PNO N/A YES NO N/A	Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7 Mgmt Personnel Name: Doug Hammer. Mgmt Personnel Title:	YES THO N/A	Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7 Mgmt Personnel Name: Does the Plan format follow the sequence in the rule? 112.7 or If no, is a cross-reference provided? Does the Plan call for additional facilities or procedures, methods, or equipment	YES PNO N/A YES NO N/A	Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7 Mgmt Personnel Name: Does the Plan format follow the sequence in the rule? 112.7 or If no, is a cross-reference provided? Does the Plan call for additional facilities or procedures, methods, or equipment not yet fully operational?	□ YES □NO □ N/A □ YES □NO □ N/A □ YES □ NO □ N/A □ YES □ NO □ N/A	Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7 Mgmt Personnel Name:	□ YES □NO □ N/A □ YES □NO □ N/A □ YES □ NO □ N/A □ YES □ NO □ N/A	Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7 Mgmt Personnel Name: Doug January Mgmt Personnel Title: January Does the Plan format follow the sequence in the rule? 112.7 or If no, is a cross-reference provided? Does the Plan call for additional facilities or procedures, methods, or equipment not yet fully operational? If yes, are the following items discussed in the Plan?	□ YES □NO □ N/A □ YES □NO □ N/A □ YES □ NO □ N/A □ YES □ NO ☑ N/A □ YES □ NO ☑ N/A	Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7 Mgmt Personnel Name: Doug land wat stop new Mgmt Personnel Title: Supervisor General Section 112.7 or If no, is a cross-reference provided? Does the Plan call for additional facilities or procedures, methods, or equipment not yet fully operational? If yes, are the following items discussed in the Plan? Installation Start-up Does the Plan include a discussion of conformance with SPCC requirements? 112.7(a)(1)	□ YES □ NO □ N/A	Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7 Mgmt Personnel Name: Mgmt Personnel Title: Does the Plan format follow the sequence in the rule? 112.7 or If no, is a cross-reference provided? Does the Plan call for additional facilities or procedures, methods, or equipment not yet fully operational? If yes, are the following items discussed in the Plan? Installation Start-up Does the Plan include a discussion of conformance with SPCC requirements? 112.7(a)(1) Does the Plan deviate from SPCC requirements? 112.7(a)(2)	□ YES □NO □ N/A □ YES □NO □ N/A □ YES □ NO □ N/A □ YES □ NO ☑ N/A □ YES □ NO ☑ N/A	Field Verification
Does the SPCC Plan indicate (by signature and date) that management has approved the plan? 112.7 Mgmt Personnel Name: Doug Homes Mgmt Personnel Title: Supervisor General Section 112.7 or If no, is a cross-reference provided? Does the Plan call for additional facilities or procedures, methods, or equipment not yet fully operational? If yes, are the following items discussed in the Plan? Installation Start-up Does the Plan include a discussion of conformance with SPCC requirements? 112.7(a)(1)	□ YES □ NO □ N/A	Field Verification

Does the Plan contain a facility diagram? 112.7(a)(3)	☐ YES ☐ NO ☒ N/A	☐ YES ☐ NO ☑ N/A
Does the diagram include:		
- The location and contents of each container?, and	☐ YES ☐ NO ☒ N/A	☐ YES ☐ NO ☒ N/A
- Completely buried storage tanks?, and	☐YES ☐ NO ☒ N/A	☐ YES ☐ NO ☒ N/A
- Transfer stations?, and	☐YES ☐ NO ☒ N/A	☐ YES ☐ NO ☒ N/A
- Connecting pipes?	☐ YES ☐ NO ☒ N/A	☐YES ☐ NO ☒ N/A
Is there a description in the Plan of the physical layout of the facility and includes: 112.7(a)(3)	YES NO NA	
- The type of oil in each container and its storage capacity? 112.7(a)(3)(i)	YES NO NA	YES NO NA
 Discharge prevention measures including procedures for routine handling of products? 112.7(a)(3)(ii) 	TYES NO NA	YES NO NA
 Discharge or drainage controls, such as secondary containment around containers, and other structures, equipment, and procedures for the control of a discharge? 112.7(a)(3)(iii) 	□YES □ NO □ N/A	YES NO NA
 Countermeasures for discharge discovery, response, and cleanup (including facility and contractor resources)? 112 7(a)(3)(iv 	□YES □NO ⊠N/A	□YES □ NO ☑ N/A
 Methods for disposal of recovered materials in accordance with applicable legal requirements? 112.7(a)(3)(v) 	□YES □NO ⊠N/A	
 Contact list and phone numbers for the facility response coordinator, NRC, cleanup contractors, and federal, state, and local agencies who must be notified in the case of a discharge as described in §112.1(b)? 112.7(a)(3)(vi) 	☐ YES ☐ NO ☒ N/A	
Does the Plan include information and procedures for reporting a discharge (exact location, phone number, date/time of material discharged, quantity, actions taken, evacuations, notifications, (names/organizations etc.)? 112.7(a)(4)	YES NO NA	
Does the Plan include procedures to use when a discharge may occur? 112.7(a)(5)	YES NO N/A	
Does the Plan include a prediction and description of major equipment failure(s) that could result in a discharge from the facility per 40 CFR 112.7(b)?	YES NO NA	
direction, rate of flow, and total quantity of oil	. /	
Does the Plan discuss appropriate containment and/or diversionary structures/equipment (dikes, berms, retaining walls, curbing, culverts, gutters/drain systems, weirs, boom, diversion/retention ponds, sorbent material) and is sufficiently impervious to contain oil. per 40 CFR 112.7(c)	YES NO NA	□ YES □ NO □ N/A
Has it been determined in the Plan, that the installation of structures or equipment (containment) is not practicable ?? 112.7(d) If YES, check ☐ then 40 CFR Part 109 Checklist must be filled out and,	□YES □NO □NIA	
- Is the impracticability clearly demonstrated?	YES NO NA	
 For bulk storage containers, is periodic integrity testing of containers and leak testing of the valves and piping associated with the container conducted? 	YES NO NA	YES NO NA
- Is a strong contingency plan per 40 CFR 109 provided? 112.7(d)(1)	YES NO NIA	1 C
 Is a written commitment of manpower, equipment, and material (to control and remove any quantity of oil discharged) provided in the SPCC plan? 112.7(d)(2 	□YES □NO ☑N/A	

Comment:		
SCHOOL WINDOWS WAS CONTROL OF SCHOOL STATE OF THE STATE O		
INSPECTIONS, TESTS, AND RECORDS 112.7(e)	Plan Review	Field Verification
Are inspections and tests required by 40 CFR 112 conducted in accordance with written procedures developed for the facility? 112.7(e)	TYES NO NA	☐ YES ☐ NO ☐ N/A
If Yes, are written procedures, records of inspections and/or customary business records:		
- Signed by the appropriate supervisor or inspector?	YES NO NA	☐ YES ☐ NO ☐ N/A
- Kept with the SPCC Plan? .	TYES NO NA	☐ YES ☐ NO ☐ N/A
- Maintained for a period of three (3) years?	DYES NO NA	□YES □NO □N/A
PERSONNEL TRAINING AND DISCHARGE PREVENTION PROCEDURES 112.7 (f)	Plan Review	Field Verification
Are oil handling personnel trained on: 112.7(f)(1)		
- The operation and maintenance of equipment to prevent the discharge of oil?	TYES NO N/A	□YES □NO □N/A
- Discharge procedure protocols (discovery and notification)?	STES ONO NA	
- Applicable pollution control laws, rules, and regulations?		YES NO N/A
- General facility operations?	YES NO N/A	YES NO NA
TO ANY CONTROL OF THE PROPERTY	YES NO N/A	
- The contents of the Plan?		YES NO NA
	YES NO NA	YES NO N/A
- The contents of the Plan?	YES NO WHA	☐ YES ☐ NO ☐ N/A ☐ YES ☐ NO ☑ N/A ☐ YES ☐ NO ☑ N/A
- The contents of the Plan? Is there a designated person accountable for spill prevention? 112.7(f)(2)	YES NO WHA	☐ YES ☐ NO ☐ N/A ☐ YES ☐ NO ☑ N/A ☐ YES ☐ NO ☑ N/A
Is there a designated person accountable for spill prevention? 112.7(f)(2) Name and title of individual?	YES NO MA	YES NO N/A YES NO MA YES NO MA YES NO MA YES NO N/A

Comment:		
Sym Am		
-		
SECURITY (excluding oil production facilities) 112.7(g)	Plan Review	Field Verification
Environmental Equivalence		
Qualified Facility [(If the facility is a "qualified facility", complete section 112.7(k) and Appendix A of this checklist.)		
Is the facility fully fenced and are entrance gates locked and/or guarded when not in production or unattended? 112.7(g)(1) $EE \square QF \square$	PYES NO NA	YES NO NA
Are master flow and drain valves that permit direct outward flow to the surface secured in closed position when in a non-operating or standby status? 112.7(g)(2	TYES NO N/A	□YES □NO □N/A
EE 🗆 QF 🗆		
Are starter controls on pumps locked in the "off" position or located at a site accessible only to authorized personnel when in non-operating or standby status? 112.7(g)(3) $EE \ \square \ QF \ \square$	DYES NO N/A	YES NO NA
Are transfers at loading/unloading (facility pipeline/piping) connections securely capped or blank-flanged when not in service or standby status? 112.7(g)(4)	DYES NO NA	□YES □NO □N/A
EE 🗆 QF 🗆		
Does the facility lighting appear to be adequate (commensurate with the type/location of the facility) to facilitate the discovery of spills during hours of darkness and to deter vandalism? 112.7(g)(5) $EE \square QF \square$	ØYES □ NO □ N/A	YES NO N/A
Comment:		

FACILITY TANK CAR AND TANK TRUCK LOADING/UNLOADING RACK, (excluding offshore facilities) 112.7(h-j)	Plan Review	Field Verification
Environmental Equivalence	and the support and the support	
Does the facility have a loading/unloading/transfer area? If yes,	EYES DNO DN/A	□YES □ NO □ N/A
 Does the facility have containment consistent with 112.7(c) as required by 112.1(a)(1) to prevent a discharge of oil to the waters of the U.S.? 	D-YES NO N/A	YES NO NA
Does drainage from loading/unloading areas and/or locations adjacent to the loading or unloading racks flow to catchment basin(s), or	TYES NO NA	YES NO NA
- Treatment system? 112.7(h)(1)	YES NO NA	☐ YES ☐ NO ☐ N/A
- If NO to either, is quick drainage system used?	YES NO THIA	□YES □NO □N/A
Are containment systems designed to hold at least the maximum capacity of any largest single compartment of a tank car or tank truck (when at the loading/unloading rack)?	DYES NO N/A	YES NO NA
Is there a system used to prevent departure (tank trucks/tank cars) before completing the disconnection from transfer lines? 112.7(h)(2) EE	□YES □ NO □ N/A	YES NO N/A
If YES, are there:		
- Interlocked warning lights? or,	YES NO NA	☐ YES ☐ NO ☐ N/A
- Physical barrier systems (i.e., wheel locks)? or,	YES NO NA	□YES □NO □N/A
- Warning signs? or,	DYES NO NA	☐ YES ☐ NO ☐ N/A
- Vehicle brake interlock system?	YES NO NIA	☐YES ☐ NO ☐ N/A
Are tank cars/tank trucks lower most drains and all outlets inspected for discharges prior to filling and departure? 112.7(h)(3), (note; do procedures ensure that they are tightened, adjusted, or replaced to prevent liquid discharge while in transit)	YES NO NA	☐ YES ☐ NO ☐ N/A
EE 🗆		
Comment		434,000 1,200,2

Does the Plan include a risk analysis and/or evaluation of field-constructed aboveground tanks for brittle fracture after tank repair/alteration/ or when a change in service has occurred? 112.7(i)	☐ YES ☐ NO ☑ N/A	□ YES □ NO ☑ N/A
Comment		
Does the Plan include a discussion of conformance with applicable requirements of the SPCC rule or any applicable state rules, regulations, and guidelines and other effective discharge prevention and containment procedures listed in 40 CFR Part 112? 112.7(j)	☐ YES ☐ NO ☒ N/A	□YES □NO ⊠N/A
Comment		
		I
QUALIFIED OIL-FILLED OPERATIONAL EQUIPMENT SECONDARY CONTAINMENT OPTION 112.7(k)	Plan Review	Field Verification
is there qualified oil-filled operational equipment at the facility? (Oil storage containers and associated piping intrinsic to the operation of the equipment in which the oil is present solely to support the function of the apparatus or the device.)	YES NO DAIA	□ YES □ NO □ N/A
Has the facility qualified for the secondary containment option? 112.7(k)		
- Has a single reportable discharge as described in §112.1(b) from any oil-filled operational equipment exceeding 1,000 U.S. gallons occurred within any 12-month period within the three years prior to Plan certification date?	YES NO NA	□ YES □ NO □N/A
- Have two reportable discharges as described in §112.1(b) from any oil-filled operational equipment each exceeding 42 U.S. gallons occurred within any 12-month period within the three years prior to Plan certification date?	YES NO NA	YES NO NA
If YES for either, secondary containment is required. See 112.7(c).		
If NO and no secondary containment is provided, then:		1
- Are facility procedures for inspections/monitoring program established and documented? 112.7(k) (2)(i)	YES NO N/A	YES NO DINA
- Does the facility maintain a Facility Response Plan? 112.7(k) (2)(ii)	YES NO NIA	YES NO NA
- Is there a Contingency plan following 40 CFR part 109 (see Appendix D checklist) provided? AND	YES NO NA	YES NO NA
 Is there a written commitment of manpower, equipment, and materials required to control and remove any quantity of oil discharged that may be harmful? 	YES NO NA	□ YES □ NO □ N/A

Comment		
FACILITY DRAINAGE 112.8(b)	Plan Review	Field Verification
Environmental Equivalence		
Is drainage from diked storage areas restrained by valves to prevent a discharge into the drainage system or facility effluent treatment system? 112.8(b)(1) EE	YES NO N/A	☐ YES ☐ NO ☐ N/A
- If YES, is the facility designed to control such discharge?	₽YES □ NO □ N/A	□YES □NO □N/A
Is drainage from diked storage areas that drain directly into a watercourse, restrained via manual, open-and-closed designed valves? 112.8(b)(2) If YES,	ØYES □ NO □ N/A	YES NO NA
EE 🗆		
- Is runoff rainwater from diked areas inspected such, that it will not cause a harmful discharge (as defined in 40 CFR 110)? 112.8(c)(3)(ii)	YES NO NA	□YES □ NO □ N/A
- Are valves opened and resealed under responsible supervision? 112.8(c)(3)(iii)	YES NO NA	□YES □NO □N/A
 Are adequate records (or NPDES permit records) of dike drainage events maintained? 112.8(c)(3)(iv) 	YES NO NA	YES NO N/A
Does drainage from undiked areas flow into catchment basins, ponds, or lagoons designed to retain oil or return it to the facility? 112.8(b)(3) EE	YES NO NA	YES NO NA
 If YES, is the catchment basin located in areas not subject to periodic flooding? 	TYES NO N/A	□YES □NO □N/A
- If NO, for the final discharge of all ditches inside the facility, is there a diversion system to retain spills in the facility? 112.8(b)(4)	YES NO DAMA	□YES □NO □N/A
Is drainage water continuously treated in more than one treatment unit in the facility? 112.8(b)(5)	YES NO NA	□YES □NO ☑N/A
- If Yes, are two "lift" pumps provided of which one is permanently installed or is the drainage system engineered to prevent a discharge in case of equipment failure or human error?	YES NO DINIA	□YES □NO □N/A
Comment:		

BULK STORAGE CONTAINERS 112.8(c) (See Container Inspection Forms)	Plan Review	Field Verification
Environmental Equivalence		
Qualified Facility [(If the facility is a "qualified facility", complete section 112.7(k) and Appendix A of this checklist.)		
Is the material and construction of containers compatible to the oil stored and to the conditions of storage such as pressure and temperature, etc.?112.8(c)(1)	YES NO NA	YES NO NA
EE 🔲	/.	
Do all container installations have secondary containment (Note: drainage trench enclosures that terminate to a facility catchment basin or holding pond may be used)? 112.8(c)(2) If Yes,	□YES □ NO □ N/A	YES NO NA
(Can not use Environmental Equivalence for this part)		
 Will the containment(s) hold the capacity of the largest single container plus sufficient freeboard for precipitation? 	YES NO NA	□YES □NO □N/A
 Are containment systems, including walls and floors, sufficiently impervious to contain discharged oil? 	TYES NO NA	□YES □NO □N/A
Is there drainage of uncontaminated rainwater from diked areas into a storm drain or open watercourse? If YES,	TYES NO NA	YES NO NA
- Are bypass valves on diked areas sealed closed when not draining uncontaminated rainwater? 112.8(c)(3)(i) EE	YES NO NA	YES NO NA
- Is retained rainwater inspected to ensure that its presence will not cause a discharge as described in §112.1(b)? 112.8(c)(3)(ii) EE □	TYES NO NA	☐ YES ☐ NO ☐ N/A
- Are bypass valve opened and resealed under responsible supervision? 112.8(c)(3)(iii) EE	YES NO NA	☐ YES ☐ NO · ☐ N/A
- Are adequate records of drainage maintained? 112.8(c)(3)(iv) EE	YES NO NA	YES NO N/A
Are there completely buried metal storage tanks at the facility? 112.8(c)(4) EE	TYES NO TO NIA	☐ YES ☐ NO ☐ N/A
- If YES, are they regulated under 40 CFR part 280 or state program approved under 40 CFR part 281? 112.1(d)(2)(i) If NO,	YES NO NA	□YES □ NO □ N/A
- Were they installed after January 10, 1974, are tanks protected from corrosion (compatible with soil conditions)? and,	YES NO NA	☐ YES ☐ NO ☐ N/A
- Are tanks subject to regular leak testing?	YES NO NA	□YES □NO □N/A
Are there partially buried containers at the facility? 112.8(c)(5) EE	YES NO NA	YES NO NA
If YES, are buried sections protected from corrosion (compatible with local soil conditions)?	YES NO NA	YES NO NA
Does the Plan indicate that visual inspections of the outside of tanks are performed? 112.8(c)(6) and,	YES NO MA	YES NO NA

Are aboveground tanks at systems of nondestructive material repairs are made	t this facility subject to periodic integrity testing, or other e shell testing (by qualified personnel) whenever $P(C) = P(C)$	☐ YES ☐ N	O PN/A	□ YES □ I	NO DNA
What type(s) and frequen	cy of test?:				
- Hydrostatic?, or	☐ Monthly ☐ Bi-annual ☐ Annual ☐ 5 yr ☐ 10 yr ☐ 15 yr	☐ YES ☐ N	O NA	YES DI	NO DNA
- Magnetic Particle?, or	☐ Monthly ☐ Bi-annual ☐ Annual ☐ 5 yr ☐ 10 yr ☐ 15 yr	☐ YES ☐ N	O N/A	□ YES □ I	NO NA
- Penetrant-dye?, or	☐ Monthly ☐ Bi-annual ☐ Annual ☐ 5 yr ☐ 10 yr ☐ 15 yr	☐ YES ☐ N	O/ N/A	YES D	NO DINA
- Ultrasonic?, or	☐ Monthly ☐ Bi-annual ☐ Annual ☐ 5 yr ☐ 10 yr ☐ 15 yr	☐ YES ☐ N	O DNIA	□YES □	NO DNA
- Radiographic?, or	☐ Monthly ☐ Bi-annual ☐ Annual ☐ 5 yr ☐ 10 yr ☐ 15 yr	☐ YES ☐ N	O N/A	□ YES □ N	O DNA
- Acoustic Emissions?, or	☐ Monthly ☐ Bi-annual ☐ Annual ☐ 5 yr ☐ 10 yr ☐ 15 yr	☐ YES ☐ N	O DNA	☐ YES ☐ N	IO . D.N/A
- Laser?, or	☐ Monthly ☐ Bi-annual ☐ Annual ☐ 5 yr ☐ 10 yr ☐ 15 yr	☐ YES ☐ N	O DINA	O YES O	IO DINA
- Other?	☐ Monthly ☐ Bi-annual ☐ Annual ☐ 5 yr ☐ 10 yr ☐ 15 yr	☐ YES ☐ N	O DN/A	□ YES □ N	IO N/A
Describe:	· · · · · · · · · · · · · · · · · · ·				
Are comparison records o records/tests) maintained	f container/tank inspections (or customary business ? 112.8(c)(6)	YES N	O N/A	☐ YES ☐ N	IO N/A
If YES, do the records	s indicate that inspection are conducted on:				
- Tank supports and	foundations?	DYES N	O N/A	□ YES □ N	IO 🗆 N/A
- Signs of deteriora	tion?	YES N	O N/A	☐ YES ☐ N	IO N/A
- Discharges?		YES N	0 N/A	YES D	IO 🗆 N/A
- Accumulation of oi		YES N	O N/A	☐ YES ☐ N	IO N/A
Are internal heating coils to	utilized? 112.8(c)(7) If YES,	☐ YES ☐ N	O DN/A	☐ YES ☐ N	IO N/A
- Do steam return/exha	ust lines discharge into open watercourse?	☐ YES ☐ N	O N/A	□ YES □ N	O N/A
 Is steam return/exhau passed through a sett system? 	ust discharging into an open watercourse monitored or ling tank, skimmer, or other separation or retention	☐ YES ☐ N	O DNIA	□ YES □ N	O DN/A
Is each containers' installa	ation engineered or updated in accordance with good	PYES N	O D N/A	☐ YES ☐ N	O D N/A
engineering practice? 112.	8(c)(8)				
(One or more of the follow	ving must be utilized.)				
- Do tanks have audible	or visual high liquid level alarms? 112.8(c)(8)(i), or	YES N	O N/A	YES ON	O D N/A
- High liquid level pump	cutoff devices? 112.8(c)(8)(ii), or	☐ YES ☐ N	O N/A	☐ YES ☐ N	0 N/A

 Audible or code signal communications between gauger and pumping station? 112.8(c)(8)(iii), or 	YES NO DAYA	□YES □ NO □ N/A
 A system of determining liquid level in containers such as digital computers, telepulse, or direct vision gauges? 112.8(c)(8)(iv) 	DYES NO N/A	YES NO NA
Are liquid level sensing devices regularly tested? 112.8(c)(8)(v)	YES NO THIA	□YES □NO □N/A
Are effluent treatment facilities observed frequently enough to detect possible system upsets that could cause a discharge as described in §112.1(b)? EE EE	₽YES □ NO □ N/A	YES NO NA
Are visible discharges which result in a loss of oil from the container, including but not limited to seams, gaskets, piping, pumps, valves, rivets, and bolts are promptly corrected and oil in diked areas is promptly removed? 112.8(c)(10))	PYES NO NA	YES NO NA
EE 🗆		
Are there mobile or portable storage units at this facility? 112.8(c)(11) If YES,	YES NO NA	☐ YES ☐ NO ☐ N/A
 Are storage containers positioned to prevent discharged oil from reaching navigable water? 	YES NO NA	YES NO NA
 Is there adequate secondary means of containment with sufficient capacity to contain the largest single compartment or container and sufficient freeboard for precipitation provided? 	YES NO NA	YES NO NA
EAGULTY TRANSFER ORERATIONS BUMBING AND FACILITY	T 51- 5	TINANG SECOND
FACILITY TRANSFER OPERATIONS, PUMPING, AND FACILITY PROCESS112.8(d)	Plan Review	Field Verification
Environmental Equivalence		
Are buried piping corrosion protected with protective wrapping and/or coating? (Must be corrosion protected on or after August 16, 2002) 112.8(d)(1), or EE	THYES NO N/A	☐ YES ☐ NO ☐ N/A
- Corrosion protected under part 280 or state program approved under part 281? 112.1(d)(2)(i)	☐YES ☐ NO ☒ N/A	☐ YES ☐ NO ☒ N/A
Are sections of exposed buried piping inspected for deterioration, and appropriate corrective action taken as needed?	□YES □NO ⊠N/A	□YES □NO ☑N/A
Are not-in-service or standby (extended time) piping, capped and blank-flanged, and marked as to their origin? $112.8(d)(2)$ EE	PYES NO NA	☐ YES ☐ NO ☐ N/A
Are pipe supports designed to minimize abrasion and corrosion, and to allow for	YES NO NA	YES NO NA

Are aboveground valves, piping and appurtenances such as flange joints, expansion joints, valve glands and bodies, catch pans, pipeline supports, locking of valves, and metal surfaces inspected regularly? 112.8(d)(4) EE	PYES NO N/A	☐ YES ☐ NO ☐ N/A
At what frequency?:		
- Daily, or	DYES NO N/A	☐ YES ☐ NO ☐ N/A
- Weekly, or	YES NO NO	□ YES □ NO □ N/A
- Monthly, or	DYES NO N/A	□YES □NO □N/A
- Bi-monthly, or	YES NO NO	□ YES □ NO □ N/A
- Annual, or	YES NO NA	□YES □NO □N/A
- Semi-annual, or	YES NO NA	□YES □NO □N/A
- Other	YES NO DINA	☐ YES ☐ NO ☐ N/A
Is periodic integrity and leak testing of buried piping (at the time of installation, modification, construction, relocation, or replacement) conducted? 112.8(d)(4)	□YES □ NO □ N/A	☐ YES ☐ NO ☐ N/A
EE 🗆		
At what frequency?:		
- Daily, or	YES NO NIA	☐ YES ☐ NO ☐ N/A
- Weekly, or	YES NO DIMA	YES NO NA
- Monthly, or	YES NO DWA	YES NO NA
- Annual, or	□ YES □ NO □ N/A	YES NO NA
- Other hymnd medificalio	DYES DNO DNA	YES NO NA
Is vehicle traffic warned of aboveground piping or other oil transfer operations? 112.8(d)(5) EE	BYES □ NO □ N/A	☐ YES ☐ NO ☐ N/A
Comment:		

Qualified Facilities Checklist

Appendix A: Qualified Facility Plan Requirements

Complete this Appendix only if the facility is a "qualified facility" as defined in §112.3(g). A qualified facility's Plan, whether certified by a PE or self-certified, must comply with all of the applicable requirements of §112.7 and subparts B and C of 40 CFR Part 112 referenced earlier in this checklist.

SPCC Inspection #: FY-INSI	-090	18	DOMESTIC STORY
112.6–Qualified Facility Plan Requirements	Yes	No	N/A
(a) Did the owner/operator of the qualified facility self-certify the SPCC Plan? If NO, see requirements for 112.3(d) above. If YES, did the owner/operator certify in the Plan that:			/
(1) He or she is familiar with the requirements of 40 CFR part 112.			
(2) He or she has visited and examined the facility.			-
(3) The Plan has been prepared in accordance with accepted and sound industry practices and standards.		-	
(4) Procedures for required inspections and testing have been established.			/
(5) The Plan is being fully implemented.		1, 1,	
(6) The facility meets the qualification criteria set forth under §112.3 (g).			/
(7) The Plan does not deviate from any requirements as allowed by §112.7(a)(2) and 112.7(d), except as described under §112.6(c).			/
(8) Management has given full approval of the Plan and necessary resources have been committed for the Plan's full implementation.			/
(b) Did the owner/operator self-certify any of the Plan's technical amendments?			/
If YES: Is the certification of any technical amendments in accordance with the provisions above (§112.6(a))?			/
(c)(1) and (d)(1) Environmental Equivalence. For each alternative measure allowed under §112.7(a)(2), the Plan is accompanied by a written statement by a PE that states the reason for nonconformance and describes the alternative method and how it provides equivalent environmental protection in accordance with §112.7(a)(2).			/
(c)(2) and (d)(1) Impracticability. For each determination of impracticability of secondary containment pursuant to §112.7(d), the Plan clearly explains why secondary containment measures are not practicable at this facility and provides the alternative measures required in §112.7(d) in lieu of secondary containment.			/
(c)(3) Security. The Plan contains one of the following:			
 (i) The Plan complies with requirements under §112.7(g), OR (ii) The Plan complies with the requirements under §112.6(c)(3)(ii): Plan describes how the owner/operator secures and controls access to the oil handling, processing and storage areas; 			/
secures master flow and drain valves; prevents unauthorized access to starter controls on oil pumps; secures out-of-service and loading/unloading connections of oil pipelines; addresses the appropriateness of security lighting to both prevent acts of vandalism and assist in the discovery of oil discharges.			
(c)(4) Bulk Storage Containers. The Plan contains one of the following: (i) The Plan complies with the requirements under §§112.8(c)(6) or 112.12(c)(6), as applicable; OR (ii) The Plan complies with the requirements under §112.6(c)(4)(ii):			
 Aboveground containers, supports and foundations tested for integrity on a regular schedule and whenever repairs are made. 			
 Appropriate qualifications for personnel performing tests and inspections have been determined in accordance with industry standards. 			
 The frequency and type of testing and inspections have been determined in accordance with industry standards, taking into account container size, configuration and design. Container supports and foundations regularly inspected 			
 Outside of containers frequently inspected for signs of deterioration, discharges, or accumulation of oil inside diked areas 			

Records of inspections and tests				-
Did a PE certify a portion of a qualified If YES, the PE must certify in the F	d facility's self-certified Plan?	34.4	Thurs	/
(2)	Turi triat.	+		-
(i) He/she is familiar with the require	ments of 40 CFR Part 112.			
(ii) He/she or a representative agent	has visited and examined the facility.			
determination of impracticability and	nmental equivalence in accordance with §112.7(a)(2) or the alternative measures in accordance with §112.7(d) is consistent		1 34	
with good engineering practice, inclu	iding consideration of applicable industry standards, and with			
the requirements of 40 CFR Part 112	2.	The second	E.6	
(4) If a DE position a series of the DI	P. L. DE U.S.			
tion of the Plan?	an, did a PE certify any technical amendments that affect this			
mments:	The second secon	1	1	
	그렇게 하게 하면 하는 이 사람들이 하는 것이 모든 사람이 없다.			

A	ppendix B: Container Inspection F	form
Container ID:	SPO	CC Inspection #: FY-INSP
Maximum capacity (gal):	Container height (ft):	
Nominal capacity (gal):	Container diameter (ft):	Year Built:
Current Status: Active Stand	by Out of service Closed	
Material(s) Stored in Container: Crude oil Gasoline Other:		☐ Vegetable oil/animal fats, grease
Container Type:		
☐ Vertical Cylindrical	☐ External Floating Roof	☐ Geodesic Dome
☐ Fixed Roof (Vented)	☐ Internal Floating Roof	Spheroid
☐ Coned Roof – (Vented)	☐ Hemispheroid (Noded)	☐ Horizontal Cylindrical
☐ Coned Roof – (Not Vented)	☐ Hemispheriod (Not Noded)	Other:
Container Material:		Tall and a second
☐ Single Wall Steel	☐ Not Painted	☐ Wooden
☐ Double Wall Steel	☐ Fiberglass Reinforced Plastic	Other:
Painted	☐ Composite (steel with fiberglass)	
Container Construction:	lded Riveted Bolted	☐ Shop Fabricated ☐ Field Erected
Container Cathodic Protection:	☐ None ☐ Sacrificial Anode(s)	☐ Impressed Current
Inspect container including the base	e for leaks, specifically looking for:	
Drips, weeps, & stains:	Discoloration of tank:	Corrosion:
☐ Check if present and check if:	☐ Check if present and check if:	☐ Check if present and check if:
Acceptable	Acceptable	Acceptable
Or, if Unacceptable,	Or, if Unacceptable □,	Or, if Unacceptable,
☐ Adequate	Adequate	☐ Adequate
Comment on container inspection:		
		7
Container Foundation Material:		
☐ Earthen Material ☐ Ring V impermeable mat.)	Vall Concrete (w/impermeable ma	at.) Concrete (w/o
Steel Unknown Othe	r:	
Inspect container foundation, spec	ifically looking for:	
Cracks:	Settling:	Gaps (between tank and
Check if present and check if:	☐ Check if present and check if:	foundation):
Acceptable	Acceptable	☐ Check if present and check if:
Or, if Unacceptable,	Or, if Unacceptable □,	Acceptable
☐ Adequate	☐ Adequate	Or, if Unacceptable [],
		Adequate

Comment on foundation inspection:			
Container Piping Construction:			
☐ Aboveground ☐ Underground	☐ Steel (ba	re) Steel (painted)
☐ Double walled ☐ Copper		ss reinforced plastic	☐ Unknown
Other:		in reminerated places	- Olikilowii
Inspect pipes/valves, specifically looking fo	r:		
Leaks at joints, seams, valves:	Discoloration:	Corr	osion:
☐ Check if present and if:	☐ Check if prese		check if present and if:
Acceptable	Accepta		Acceptable
Or, if Unacceptable,	Or, if Unacce	eptable [],	Or, if Unacceptable [],
☐ Adequate	☐ Adequate	_ A	dequate
Bowing of pipe:	Pooling of store	d material:	
☐ Check if present and if:	☐ Check if prese	ent and if:	
Acceptable	Accepta	able 🗌	
Or, if Unacceptable ,	Or, if Unacce	eptable [],	
Adequate	☐ Adequate		
Comment on piping/valve inspection:			
Secondary Containment Types:	¥		
☐ Dikes/berms/retaining walls	Curbing	☐ Culverts and/or gutters	☐ Spill diversion ponds
☐ Sorbent Materials	Retention Ponds	☐ Weirs and/or booms	
Other – Loc.:			
Secondary Containment Checklist:	- 18 St. 4		
☐ Capacity does not appear to be adequate?		☐ Drainage mechanism r	nanually operated?
Not sufficiently impervious to stored materia	il?	☐ Presence of stored ma	terial within dike or berm?
Standing water within dike or berm?		☐ Debris/vegetation withi	n or on the dike or berm area?
☐ Erosion or corrosion of dike or berm?			
Location:	¥	. William Property	· · · · · · · · · · · · · · · · · · ·
Comment on containment inspection:			
,			
		100	

SPCC CONTINGENCY PLAN REVIEW CHECKLIST

Appendix C: 40 CFR Part 109–Criteria for State, Local and Regional Oil Removal Contingency Plans

NA

If a facility makes an impracticability determination for secondary containment in accordance with §112.7(d), it is required to provide an oil spill contingency plan following 40 CFR, part 109. Items below must be addressed in the Plan and implemented at the facility.

SPCC Inspection # FV_INSP. (5951.8)

109.5—Development and implementation criteria for State, local and regional oil removal contingency plans*	Yes	No
(a) Definition of the authorities, responsibilities and duties of all persons, organizations or agencies which are to be involved in planning or directing oil removal operations.		
(b) Establishment of notification procedures for the purpose of early detection and timely notification of an oil discharge including:		
(1) The identification of critical water use areas to facilitate the reporting of and response to oil discharges.		
(2) A current list of names, telephone numbers and addresses of the responsible persons (with alternates) and organizations to be notified when an oil discharge is discovered.		
(3) Provisions for access to a reliable communications system for timely notification of an oil discharge, and the capability of interconnection with the communications systems established under related oil removal contingency plans, particularly State and National plans (e.g., NCP).		
(4) An established, prearranged procedure for requesting assistance during a major disaster or when the situation exceeds the response capability of the State, local or regional authority.		
(c) Provisions to assure that full resource capability is known and can be committed during an oil discharge situation including:		
(1) The identification and inventory of applicable equipment, materials and supplies which are available locally and regionally.		
(2) An estimate of the equipment, materials and supplies which would be required to remove the maximum oil discharge to be anticipated.		
(3) Development of agreements and arrangements in advance of an oil discharge for the acquisition of equipment, materials and supplies to be used in responding to such a discharge.		
(d) Provisions for well defined and specific actions to be taken after discovery and notification of an oil discharge including:		
(1) Specification of an oil discharge response operating team consisting of trained, prepared and available operating personnel.		
(2) Pre-designation of a properly qualified oil discharge response coordinator who is charged with the responsibility and delegated commensurate authority for directing and coordinating response operations and who knows how to request assistance from Federal authorities operating under existing national and regional contingency plans.		
(3) A preplanned location for an oil discharge response operations center and a reliable communications system for directing the coordinated overall response operations.		
(4) Provisions for varying degrees of response effort depending on the severity of the oil discharge.		
(5) Specification of the order of priority in which the various water uses are to be protected where more than one water use may be adversely affected as a result of an oil discharge and where response operations may not be adequate to protect all uses.		
(e) Specific and well defined procedures to facilitate recovery of damages and enforcement measures as provided for by State and local statutes and ordinances.		

Environmental Equivalence (EE) Checklist

Appendix D: Environmental Equivalence Requirements

MA

Complete this Appendix only if the facility has declared "environmental equivalence" measures as described in § 112.7(a)(2). Facility owners and operators have the flexibility to deviate from specific rule provisions if the Plan states the reason for nonconformance and if equivalent environmental protection is provided by some other means of SPCC. EE declarations must be certified by a PE. For EE declarations, see portions of checklist referenced earlier.

SPCC Citation:	SPCC Inspection #: FY-II	VSP- 690182
Is there written documentation validating/explaining rational requirements?	for non-conformance with the SPCC	YES NO
Is there written documentation outlining/detailing how the all environmental equivalence? and,	ternative method achieves	YES NO
Is the alternative method:		
Technically feasible?		YES NO
Logistically sound?		YES NO
Practicable?		YES NO
Name of Professional Engineer:		
	ate:	
Other PE certification requirements:		
Did a PE certify a portion of a qualified facility's self-certified	Plan? YES NO	
Description of environmental equivalence:		
Inspector Comment:		

^{*} Use additional Appendix D forms for multiple Environmental Equivalent declarations.

Spill Prevention Control and Countermeasure Inspection Findings, Alleged Violations, and Proposed Penalty Form

(Note: Do not use this form if there is no secondary containment)

These Findings, Alleged Violations and Penalties are issued by EPA Region 6 under the authority vested in the Administrator of EPA by Section 311(b)(6)(B)(I) of the Clean Water Act, as amended by the Oil Pollution Act of 1990.

Company Name	Docket Number:
	C W A 6 - - *
Facility Name	Date
	MAN PROTECTION
Address	Inspection Number
	FY-INSP-
City:	Inspectors Name:
State: Zip Code:	EPA Approving Official:
Contact:	Enforcement Contacts:
	Nelson Smith (214)665-8489 Bryant Smalley (214)665-7368
(Bull	mary of Findings k Storage Facilities) (a),(e); 112.5(a), (b), (c); 112.7 (a), (b), (c), (d) & (j)
(Bulk GENERAL TOPICS: 112.3(a),(d	k Storage Facilities)
(Bulk GENERAL TOPICS: 112.3(a),(d	k Storage Facilities) (a),(e); 112.5(a), (b), (c); 112.7 (a), (b), (c), (d) & (j) (ds \$1,000.00 enter only the minimum allowable of \$1,000.00.)
(Bulk GENERAL TOPICS: 112.3(a),(d (When the SPCC Plan review penalty excee	k Storage Facilities) (a),(e); 112.5(a), (b), (c); 112.7 (a), (b), (c), (d) & (j) (ds \$1,000.00 enter only the minimum allowable of \$1,000.00.) The Plan- 112.3
(Bulk GENERAL TOPICS: 112.3(a),(d (When the SPCC Plan review penalty excee	k Storage Facilities) (a),(e); 112.5(a), (b), (c); 112.7 (a), (b), (c), (d) & (j) (ds \$1,000.00 enter only the minimum allowable of \$1,000.00.) The Plan- 112.3
(Bulk GENERAL TOPICS: 112.3(a),(d (When the SPCC Plan review penalty excee No Spill Prevention Control and Countermeasur Plan not certified by a professional engineer- 11 No management approval of plan- 112.7	k Storage Facilities) (a),(e); 112.5(a), (b), (c); 112.7 (a), (b), (c), (d) & (j) (ds \$1,000.00 enter only the minimum allowable of \$1,000.00.) The Plan- 112.3
(Bulk GENERAL TOPICS: 112.3(a),(d (When the SPCC Plan review penalty excee No Spill Prevention Control and Countermeasur Plan not certified by a professional engineer- 11 No management approval of plan- 112.7	k Storage Facilities) (a),(e); 112.5(a), (b), (c); 112.7 (a), (b), (c), (d) & (j) (ds \$1,000.00 enter only the minimum allowable of \$1,000.00.) The Plan- 112.3 (2.3(d)
(Bulk GENERAL TOPICS: 112.3(a),(d (When the SPCC Plan review penalty exceed) No Spill Prevention Control and Countermeasure Plan not certified by a professional engineer- 11 No management approval of plan- 112.7 Plan not maintained on site (applies if facility is	k Storage Facilities) (a),(e); 112.5(a), (b), (c); 112.7 (a), (b), (c), (d) & (j) (ds \$1,000.00 enter only the minimum allowable of \$1,000.00.) The Plan- 112.3 (2.3(d)) (3.2) (4.3) (5.4) (5.4) (6.4) (7.4) (8.4) (9.4
(Bulk GENERAL TOPICS: 112.3(a),(d (When the SPCC Plan review penalty exceed No Spill Prevention Control and Countermeasure Plan not certified by a professional engineer- 11 No management approval of plan- 112.7 Plan not maintained on site (applies if facility is Plan not available for review- 112.3(e)(1)	k Storage Facilities) (a),(e); 112.5(a), (b), (c); 112.7 (a), (b), (c), (d) & (j) (ds \$1,000.00 enter only the minimum allowable of \$1,000.00.) The Plan- 112.3 (2.3(d) (3.4) (4.4) hours per day)- 112.3(e)(1) (5.4) (6.4) her/operator- 112.5(b) (7.5) change in: design, construction, operation,
(Bulk GENERAL TOPICS: 112.3(a),(d (When the SPCC Plan review penalty exceed) No Spill Prevention Control and Countermeasure Plan not certified by a professional engineer- 11 No management approval of plan- 112.7 Plan not maintained on site (applies if facility is plan not available for review- 112.3(e)(1) No evidence of five-year review of plan by own No plan amendment(s) if the facility has had a contraction of the series of	k Storage Facilities) (a),(e); 112.5(a), (b), (c); 112.7 (a), (b), (c), (d) & (j) (ds \$1,000.00 enter only the minimum allowable of \$1,000.00.) The Plan- 112.3 (2.3(d) (3.4) (4.4) hours per day)- 112.3(e)(1) (5.4) (6.4) the properator of the properation of the potential
(Bulk GENERAL TOPICS: 112.3(a),(d (When the SPCC Plan review penalty exceed) No Spill Prevention Control and Countermeasure Plan not certified by a professional engineer- 11 No management approval of plan- 112.7 Plan not maintained on site (applies if facility is Plan not available for review- 112.3(e)(1) No evidence of five-year review of plan by own No plan amendment(s) if the facility has had a cormaintenance which affects the facility's disclarate.	k Storage Facilities) (a),(e); 112.5(a), (b), (c); 112.7 (a), (b), (c), (d) & (j) (d)

	Plan does not discuss conformance with SPCC requirement- 112.7(a)(1)	
	Plan does not discuss alternative environmental protection to SPCC requirements- 112.7(a)(2)	
	Plan has inadequate or no facility diagram- 112.7(a)(3)	
	Plan has inadequate or no description of the physical layout of the facility- 112.7(a)(3)(i-vi)	
	Plan has inadequate or no information and procedures for reporting a discharge- 112.7(a)(4)	
	Plan has inadequate or no description and procedures to use when a discharge may occur- 112.7(a)(5)	
	Inadequate or no prediction of equipment failure which could result in discharges- 112.7(b)	
	Plan does not discuss and/or facility does not implement appropriate containment/diversionary structures/equipment (including transfer areas)- 112.7(c)	
If cla	iming impracticability of appropriate containment/diversionary structures:	
	Impracticability has not been clearly denoted and demonstrated- 112.7(d)	
	No contingency plan- 112.7(d)(1)	
	No written commitment of manpower, equipment, and materials- 112.7(d)(2)	
	Plan has inadequate or no discussion of conformance with SPCC rules or applicable State rules, regulations and guidelines- 112.7(j)	
	WRITTEN PROCEDURES AND INSPECTION RECORDS 112.7(e)	
-		
	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e)	
	Inspections and tests required by 40 CFR Part 112 are not in accordance with written procedures developed for the facility- 112.7(e) Written procedures and/or a record of inspections and/or customary business records:	
	procedures developed for the facility- 112.7(e)	
	procedures developed for the facility- 112.7(e) Written procedures and/or a record of inspections and/or customary business records:	
	written procedures and/or a record of inspections and/or customary business records: Are not signed by appropriate supervisor or inspector- 112.7(e)	
	written procedures and/or a record of inspections and/or customary business records: Are not signed by appropriate supervisor or inspector- 112.7(e) Are not kept with the plan- 112.7(e)	
	written procedures and/or a record of inspections and/or customary business records: Are not signed by appropriate supervisor or inspector- 112.7(e) Are not kept with the plan- 112.7(e) Are not maintained for three years- 112.7(e)	
	Written procedures and/or a record of inspections and/or customary business records: Are not signed by appropriate supervisor or inspector- 112.7(e) Are not kept with the plan- 112.7(e) Are not maintained for three years- 112.7(e) PERSONNEL TRAINING AND DISCHARGE PREVENTION PROCEDURES 112.7(f)	
	Written procedures and/or a record of inspections and/or customary business records: Are not signed by appropriate supervisor or inspector- 112.7(e) Are not kept with the plan- 112.7(e) Are not maintained for three years- 112.7(e) PERSONNEL TRAINING AND DISCHARGE PREVENTION PROCEDURES 112.7(f) No training on the operation and maintenance of equipment to prevent discharges- 112.7(f)(1)	
	Written procedures and/or a record of inspections and/or customary business records: Are not signed by appropriate supervisor or inspector- 112.7(e) Are not kept with the plan- 112.7(e) Are not maintained for three years- 112.7(e) PERSONNEL TRAINING AND DISCHARGE PREVENTION PROCEDURES 112.7(f) No training on the operation and maintenance of equipment to prevent discharges- 112.7(f)(1) No training on discharge procedure protocols- 112.7(f)(1)	
	Written procedures and/or a record of inspections and/or customary business records: Are not signed by appropriate supervisor or inspector- 112.7(e) Are not kept with the plan- 112.7(e) Are not maintained for three years- 112.7(e) PERSONNEL TRAINING AND DISCHARGE PREVENTION PROCEDURES 112.7(f) No training on the operation and maintenance of equipment to prevent discharges- 112.7(f)(1) No training on discharge procedure protocols- 112.7(f)(1) No training on the applicable pollution control laws, rules, and regulations- 112.7(f)(1)	
	Written procedures and/or a record of inspections and/or customary business records: Are not signed by appropriate supervisor or inspector- 112.7(e) Are not kept with the plan- 112.7(e) Are not maintained for three years- 112.7(e) PERSONNEL TRAINING AND DISCHARGE PREVENTION PROCEDURES 112.7(f) No training on the operation and maintenance of equipment to prevent discharges- 112.7(f)(1) No training on discharge procedure protocols- 112.7(f)(1) No training on the applicable pollution control laws, rules, and regulations- 112.7(f)(1) No training on general facility operations- 112.7(f)(1)	
	Written procedures and/or a record of inspections and/or customary business records: Are not signed by appropriate supervisor or inspector- 112.7(e) Are not kept with the plan- 112.7(e) Are not maintained for three years- 112.7(e) PERSONNEL TRAINING AND DISCHARGE PREVENTION PROCEDURES 112.7(f) No training on the operation and maintenance of equipment to prevent discharges- 112.7(f)(1) No training on the applicable pollution control laws, rules, and regulations- 112.7(f)(1) No training on general facility operations- 112.7(f)(1) No training on the contents of the SPCC Plan- 112.7(f)(1)	

SECURITY (excluding Production Facilities) 112.7(g)

Facility not fully fenced and entrance gates are not locked and/or guarded when plant is unattended or not in production- 112.7(g)(1)			
Master flow and drain valves that permit direct outward flow to the surface are not secured in closed position when in a non-operating or standby status- $112.7(g)(2)$			
Starter controls on pumps are not locked in the "off" position or located at a site accessible only to authorized personnel when pumps are not in a non-operating or standby status- $112.7(g)(3)$			
Loading and unloading connection(s) of piping/pipelines are not capped or blank-flanged when not in service or standby status- $112.7(g)(4)$			
Facility lighting not adequate to facilitate the discovery of spills during hours of darkness and to deter vandalism- $112.7(g)(5)$			
Plan has inadequate or no discussion of facility security			
FACILITY TANK CAR AND TANK TRUCK LOADING/UNLOADING RACK 112.7(h)			
Inadequate secondary containment, and/or rack drainage does not flow to catchment basin, treatment system, or quick drainage system- 112.7(h)(1)			
Containment system does not hold at least the maximum capacity of the largest single compartment of any tank car or tank truck- 112.7(h)(1)			
There are no interlocked warning lights, or physical barrier system, or warning signs, or vehicle brake interlock system to prevent vehicular departure before complete disconnect from transfer lines- 112.7(h)(2)			
There is no inspection of lowermost drains and all outlets prior to filling and departure of any tank car or tank truck- $112.7(h)(3)$			
Plan has inadequate or no discussion of facility tank car and tank truck loading/unloading rack.			
FACILITY DRAINAGE FROM DIKED AREAS 112.8(b) & (c)			
Valves used for drainage from diked storage areas to drainage system, watercourse, or effluent treatment system not controlled to prevent a discharge- 112.8(b)(2)			
Run-off rainwater from diked areas is not inspected- 112.8(c)(3)(ii)			
Valves not opened and resealed under responsible supervision-112.8(c)(3)(iii)			
Adequate records (or NPDES permit records) of drainage from diked areas not maintained- 112.8(c)(3)(iv)			
FACILITY DRAINAGE FROM UNDIKED AREAS 112.8(b)			
Drainage from undiked areas do not flow into catchment basins ponds, or lagoons, or no diversion systems to retain or return a discharge to the facility or final discharge of all ditches inside facility do not have diversion system to retain spill in facility- 112.8(b)(3)&(4)			
Two "lift" pumps are not provided for more that one treatment unit- 112.8(b)(5)			
Plan has inadequate or no discussion of facility drainage			

BULK STORAGE CONTAINERS 112.8(c) & (i)

	되었다. 하는 이번 이번 생각하는 그 그 사람은 아이 아니다. 그는 것이 이 없고 그는 수가 가지 않아 가지 않아 되었다. 얼마는 아이는 아이는 아이를 하는데 없다.
П	Plan has inadequate or no risk analysis and/or evaluation of field-constructed aboveground tanks for brittle fracture- 112.7(i)
	Material and construction of tanks not compatible to the oil stored and the conditions of storage such as pressure and temperature- $112.8(c)(1)$
	Secondary containment appears to be inadequate- 112.8(c)(2)
	Containment systems, including walls and floors are not sufficiently impervious to contain oil- 112.8(c)(2)
	Excessive vegetation which affects the integrity and/or walls slightly eroded
	Containment bypass valves are not sealed closed when not draining rainwater- 112.8(c)(3)(i)
	Completely buried tanks are not protected from corrosion or are not subjected to regular pressure testing- $112.8(c)(4)$
	Partially buried tanks do not have buried sections protected from corrosion- 112.8(c)(5)
	Aboveground tanks are not subject to visual inspections- 112.8(c)(6)
	Aboveground tanks are not subject to periodic integrity testing, such as hydrostatic, nondestructive methods, etc 112.8(c)(6)
	Records of inspections (or customary business records) do not include inspections of tank supports/foundation, deterioration, discharges and/or accumulations of oil inside diked areas- 112.8(c)(6)
	Steam return /exhaust of internal heating coils which discharge into an open water course are not monitored, passed through a settling tank, skimmer, or other separation system- $112.8(c)(7)$
Con	tainer installations are not engineered if:
	No audible or visual high liquid level alarm- 112.8(c)(8)(i), or
	No high liquid level pump cutoff devices- 112.8(c)(8)(ii), or
	No audible or code signal communications between tank gauger and pumping station- 112.8(c)(8)(iii), or
	No fast response system for determining liquid levels, such as computers, telepulse or direct vision gauges- 112.8(c)(8)(iv)
	No testing of liquid level sensing devices to ensure proper operation- 112.8(c)(8)(v)
	Effluent treatment facilities which discharge directly to navigable waters are not observed frequently to detect oil spills- $112.8(c)(9)$
	Causes of leaks resulting in accumulations of oil in diked areas are not promptly corrected- 112.8(c)(10)
	Mobile or portable storage containers are not positioned to prevent discharged oil from reaching navigable water- 112.8(c)(11)
	Secondary containment inadequate for mobile or portable storage tanks- 112.8(c)(11)
	Plan has inadequate or no discussion of bulk storage tanks

FACILITY TRANSFER OPERATIONS, PUMPING, AND FACILITY PROCESS 112.8(d)

Buried piping is not corrosion protected with protective wrapping, coating, or cathodic protection -112.8(d)(1)
Corrective action is not taken on exposed sections of buried piping when deterioration is found- 112.8(d)(1)
Not-in-service or standby piping are not capped or blank-flanged and marked as to origin- 112.8(d)(2)
Pipe supports are not properly designed to minimize abrasion and corrosion, and allow for expansion and contraction- $112.8(d)(3)$
Aboveground valves, piping and appurtenances are not inspected regularly- 112.8(d)(4)
Periodic integrity and leak testing of buried piping is not conducted- 112.8(d)(4)
Vehicle traffic is not warned of aboveground piping or other oil transfer operations- 112.8(d)(5)
Plan has inadequate or no discussion of facility transfer operations, pumping, and facility process.




All rights reserved. Use subject to License/Copyright Map Legend
Directions and maps are informational only. We make no warranties on the accuracy of their content, road conditions or route usability or expeditiousness. You assume all risk of use. MapQuest and its suppliers shall not be liable to you for any loss or delay resulting from your use of MapQuest. Your use of MapQuest means you agree to our Terms of Use

MAPQUEST.



A: Latitude: 35.3094, Longitude: -94.3939: Fort Smith, AR 72908



All rights reserved. Use subject to License/Copyright Map Legend
Directions and maps are informational only. We make no warranties on the accuracy of their content, road conditions or route usability or expeditiousness. You assume all risk of use. MapQuest and its suppliers shall not be liable to you for any loss or delay resulting from your use of MapQuest. Your use of MapQuest means you agree to our Terms of Use

MAPQUEST.



A: Latitude: 35.3094, Longitude: -94.3939: Fort Smith, AR 72908

Container Inspection Form

Maximum capacity (gal):		131,
Nominal capacity (gal):	Container diameter (ft): 47	Year Built: 1953
Current Status: Active Star	ndby Out of service Closed	
Material(s) Stored in Container: Crude oil Gasoline Other:	Diesel Fuel oil Jet fuel	☐ Vegetable oil/animal fats, grease
Container Type:		
Vertical Cylindrical	☐ External Floating Roof	☐ Geodesic Dome
Fixed Roof (Vented)	☐ Internal Floating Roof	☐ Spheroid
☐ Coned Roof – (Vented)	☐ Hemispheroid (Noded)	☐ Horizontal Cylindrical
☐ Coned Roof – (Not Vented)	☐ Hemispheriod (Not Noded)	Other:
Container Material:		
Single Wall Steel	□ Non-Painted	□ Wooden
☐ Double Wall Steel	☐ Fiberglass Reinforced Plastic	Other:
Painted	☐ Composite (steel with fiberglass)	
Container Construction:	lided Riveted Bolted	☐ Shop Fabricated ☐ Field Erected
Container Cathodic Protection:	☐ None ☐ Sacrificial Anode(s)	Impressed Current
Inspect container including the bas	e for leaks, specifically looking for:	
Drips, weeps, & stains:	Discoloration of tank:	Corrosion:
☐ Check if present & check if:	☐ Check if present & check if:	☐ Check if present & check if:
Acceptable	Acceptable	Acceptable
Or, if Unacceptable □,	Or, if Unacceptable ,	Or, if Unacceptable .
Adequate	Adequate	☐ Adequate
Comment on container inspection:		
Container Foundation Material:	1	
☐ Earthen Material ☐ Ring Wall	Concrete (w/impermeable mat.)	Concrete (w/o impermeable mat.)
☐ Steel ☐ Unknown Other: _		
Inspect container foundation, specif	fically looking for:	
Cracks:	Settling:	Gaps (between tank and foundation):
☐ Check if present & check if:	☐ Check if present & check if:	☐ Check if present & check if:
Acceptable	Acceptable	Acceptable
or, if Unacceptable □,	Or, if Unacceptable ,	Or, if Unacceptable □,
Adequate	Adequate	☐ Adequate

Container Inspection Form Comment on foundation inspection: **Container Piping Construction:** Aboveground ☐ Underground ☐ Steel (bare) ☐ Steel (painted) ☐ Steel (galvanized) ☐ Copper ☐ Double walled ☐ Fiberglass reinforced plastic ☐ Unknown Other: Inspect pipes/valves, specifically looking for: Leaks at joints, seams, valves: Discoloration: Corrosion: ☐ Check if present & if: ☐ Check if present & if: ☐ Check if present & if: Acceptable Acceptable Acceptable Or, if Unacceptable . Or, if Unacceptable . Or, if Unacceptable , ☐ Adequate Adequate ☐ Adequate Bowing of pipe: Pooling of stored material: ☐ Check if present & if: ☐ Check if present & if: Acceptable Acceptable Or, if Unacceptable , Or, if Unacceptable , Adequate Adequate Comment on piping/valve inspection: **Secondary Containment Types:** Dikes/berms/retaining walls ☐ Curbing ☐ Culverts and/or gutters ☐ Spill diversion ponds ☐ Sorbent Materials Retention ☐ Weirs and/or booms **Ponds** Other - Loc.: **Secondary Containment Checklist:** ☐ Capacity does not appear to be adequate? ☐ Drainage mechanism manually operated? ■ Not sufficiently impervious to stored material? Presence of stored material w/in dike or berm? ☐ Standing water within dike or berm? ☐ Debris/vegetation within or on the dike or berm area? ☐ Erosion or corrosion of dike or berm? Location: Comment on containment inspection:

FRP/SPCC Field Inspection Verification List

FRP			
6	Training Records		
	Records of tank inspections		
	Records of secondary containment inspections		
	Response Equipment Checklist		
	Response Equipment Inspection Log		
	Response Equipment Testing and Deployment Drill Log		
0	Qualified Individual Notification Drill Log		
	Spill Management Team Tabletop Drill Log		
	Discharge Prevention Meeting Logs		
0	Response equipment (take photographs)		
SPCC			
	Training Records		
	Records of inspections and/or customary business records		